

# HUNTON FIBER AS

## Oversikt over tester.

Dato : 26.08.04

Nr.	Konstruksjon av etasjeskiller	Materiale	Overgulv	Rw dB luft	Ln dB trinn		Test dato	ANM.
<b>BETONGDEKKE</b>								
1	Betong 200mm	Silencio 36	14mm parkett		51	Multiconsult	21.12.1999	
2	Betong 200mm	Silencio Thermo	12mm parkett	62	51	J & W	14.01.2002	
3	Betong 200mm	Silencio Thermo	12mm parkett	58	49	J & W	14.01.2002	
4	Betong 220mm	Silencio 6mm	14mm parkett		53	Sinus	26.08.2003	
5	Betong 220mm	Silencio 12mm	14mm parkett		50	Sinus	26.08.2003	
6	Betong 220mm	Silencio 36mm	14mm parkett		49	Sinus	26.08.2003	
7	Betong 230mm	Silencio 36	14mm parkett		49	Beregnet	21.12.1999	
8	Betong 250mm	Silencio 36	14mm parkett		48	Beregnet	21.12.1999	
<b>HULLDEKKE</b>								
9	Hulldekke 200mm	Silencio 36	9mm kilfals + beleg	53	48	NBI	18.02.2000	Multielement i vegger.
10	Hulldekke 265mm				80	NBI	24.02.2000	
11	Hulldekke 265mm	3mm ullpapp	14mm parkett		58	NBI		Byggforskserien
12	Hulldekke 265mm	Silencio 4	14mm parkett		56	NBI	24.02.2000	
13	Hulldekke 265mm	Silencio 6	7mm laminat		55	NBI	24.02.2000	
14	Hulldekke 265mm	Silencio 6	14mm parkett		55	NBI	24.02.2000	
15	Hulldekke 265mm	Silencio 36	14mm parkett		52	NBI	24.02.2000	
16	Hulldekke 265mm	Silencio Thermo	14mm parkett		50	NBI	24.02.2000	
17	Hulldekke 265mm	Silencio Thermo	14mm parkett+6mm gips		50	NBI	24.02.2000	
18	Hulldekke 265mm	Silencio Thermo	22mm parkett		53	NBI	24.02.2000	Heltreparert
<b>LETTBETONGDEKKE</b>								
19	Leca 200mm	Silencio 36mm	14mm parkett + 6mm Silencio + 13mm gips	59	53	NBI	23.05.2002	Kun 1 lag gips i himling
<b>TREBJELKELAG</b>								
20	Trebjelkelag	Silencio 36	9mm trefiber + beleg	58	49	SINTEF	21.05.1996	Tynt beleg benyttet
21	Trebjelkelag	Silencio 36	14mm parkett	58	53	NBI	1998	
22	Trebjelkelag	Silencio 36	14mm+6mm gips	57	51	NBI	28.10.1999	
23	Trebjelkelag	Silencio 36	14mm parkett		49	ITA	nov.98	Lab.test, Tyskland
24	Trebjelkelag	Silencio 36	14mm parkett	58	52	Multiconsult	apr.99	
25	Trebjelkelag	Silencio 36	14mm parkett	58	56	NBI	mar.98	Rehabilitering