

Mulcol International
 Arnesteinweg 18
 4338 PD Middelburg
 NETHERLANDS

Eurofins Product Testing A/S
 Smedeskovvej 38
 8464 Galten
 Denmark

CustomerSupport@eurofins.com
 www.eurofins.com

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD

2 February 2023

1 Sample Information

| | |
|------------------------|----------------|
| Sample name | Multisealant A |
| Batch no. | LP005 |
| Stated production date | 16/11/2022 |
| Product type | Joint sealant |
| Sample reception | 14/12/2022 |

2 Brief Evaluation of the Results

| Regulation or protocol | Conclusion | Version of regulation or protocol |
|-------------------------|---|--|
| French VOC Regulation |  | Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A) |
| French CMR components | Pass | Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A) |
| Italian CAM Edilizia | Pass | DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022 |
| ABG/AgBB | Pass | Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021) |
| Belgian Regulation | Pass | Royal decree of May 2014 (C-2014/24239) |
| EMICODE | EC 1 PLUS | September 2022 |
| Indoor Air Comfort | Pass | Indoor Air Comfort 8.0 of June 2022 |
| Indoor Air Comfort GOLD | Pass | Indoor Air Comfort GOLD 8.0 of June 2022 |
| Blue Angel (DE-UZ 123) | Pass | DE-UZ 123 for "Low-Emission Sealants for Interior Use", (January 2019) |
| BREEAM International | Exemplary Level | BREEAM International New Construction v6.0 (2021) |
| BREEAM NOR | Exemplary Level | BREEAM-NOR v6.0 New Construction (2022) |

Full details based on the testing and direct comparison with limit values are available in the following pages
 Regarding pass/fail decision rule please see appendix



Liva Kjær Hansen
 Analytical Service Manager



Rasmus Verdier
 Analytical Service Manager