

Certificate

Indoor Air Quality Level Tarkett Platinum



Tarkett Heterogeneous PVC Flooring: iD Selection 40, iD Inspiration 55/70





Product / product group

TARKETT GmbH, Granastraße 122, 54329 Konz, Germany

Manufacturer


The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Tarkett Platinum certification, version 1.0 (2012). This includes continuous VOC emission chamber tests and an annual audit of the manufacturing site.

Successful evaluation means:

-  Sum of VOC (TVOC) was below the limit values of $10 \mu\text{g}/\text{m}^3$ after 28 days.
-  Quality management system and factory production control program at production site complied with the requirements of Eurofins Internal Tarkett VOC emission checks are regularly retested from Eurofins.
-  Therefore the product qualifies for the indoor air quality label level Tarkett Platinum.
-  No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France. The product was classified A+ according to French VOC regulation.

Certificate No.:	2013 - IATP - 02
Date:	01/08/2013
Validity of certificate:	01/08/2014


Sécurité chimique de Certification Directeur


Manager General

Eurofins Product Testing A/S
Tel. +45 70 22 42 76

ProductTesting@eurofins.com
www.product-testing.eurofins.com