

# Attestation

## EMICODE

On 3 September 2020, Eurofins Product Testing A/S received a sample of a levelling compound with the product name:

**SikaMonoTop - 3020**

supplied by

**Sika Österreich GmbH**

The emissions of organic compounds from the sample were measured in accordance with the test method as defined by GEV in its version by 24.11.2015. (See report No. 392-2020-00379002\_A\_EN)

### Evaluation of the test result according to EC 1 PLUS:

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 750 µg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was below the limit of 60 µg/m<sup>3</sup>.
- The sum of SVOC after 28 day was below the limit of 40 µg/m<sup>3</sup>.
- The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 40 µg/m<sup>3</sup>.


This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

15 October 2020



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry