



# Confirmation

Eurofins Product Testing A/S confirms that a sample with the name

**IPT Sealand**  
supplied by  
**Protecta AS**

showed low VOC contents in a test in accordance with SCAQMD rule 1168 as specified in LEED 2009 credit c4.1 (adhesives and sealants). VOC contents were below the limit values for multipurpose construction adhesives, substrate specific application: metal to metal plastic foams, porous materials (except wood), wood, fibreglass and following sealants: architectural, nonmembrane roof, roadway, single-ply roof membrane and other.

The test has been performed in December 2012, see test report no. G17855.

Volatiles content was calculated by Eurofins.  
Water content was given by the client.  
Content of exempt compounds was set to zero.  
Solids content was determined by Eurofins.

**With this confirmation, use of the tested product may qualify for fulfilment of LEED 2009 credit EQ c4.1 (adhesives and sealants).**

---

10 December 2012

---

Thomas Neuhaus  
Head of product emission test centre

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK 8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75

[www.product-testing.eurofins.com](http://www.product-testing.eurofins.com)