



EC CERTIFICATE

CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 2821-CPR-0203

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer: Polyseam Ltd
Address: 15. St. Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK
Product: GRAFT IPT Multi Sealant & Adhesive
Places of production: A/003
Harmonized requirements: EAD 350454-00-1104, September 2017 and EAD 350141-00-1106, September 2017
Scope of certificate: ETA-21/0843, issued on 18/10/2021 and ETA-21/0842, issued on 18/10/2021
Product area code: 35, Fire stopping, fire sealing and fire protective products

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA-21/0843 and ETA-21/0842, and EAD 350454-00-1104 and EAD 350141-00-1106 under system 1 (or 1+) for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 21st December 2021 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The validity of the certificate may be confirmed by contacting UL International (NL) B.V. via e-mail address info.nl@ul.com

Revision: **2**
Date of revision: **27th January 2022**

Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 

Name: Horst Thelen
Head of Notified Body

EC CERTIFICATE

Schedule for certificate No. 2821-CPR-0203

General Information

Product Reference:	GRAFT IPT Multi Sealant & Adhesive
Type:	Firestop - Sealant used as a penetration seal and linear joint seal
Description:	A sealant used to seal around metallic pipes and plastic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant may also be used to seal linear gaps and joints in and between wall and floor constructions to reinstate the fire resistance performance of wall and floor constructions, where they abut or include gaps.
Key Performance parameters:	See ETA-21/0843 and ETA-21/0842
Identification and intended use	GRAFT IPT Multi Sealant & Adhesive is supplied in liquid form contained within 200 ml, 300 ml, 380 mm and 600 ml containers. The sealant is gunned into the aperture in or between the separating element/elements and where appropriate around the service or services, to a specified depth utilising various backing materials.
CE marking method	Label on packaging
UL Project:	4790164829

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, the Technical Data Sheet and the ETA.
Limitations	See Technical Data Sheet and the ETA

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE

Revision: **2**
Date of revision: **27th January 2022**

Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 

Name: Horst Thelen
Head of Notified Body