



EC CERTIFICATE

CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 2821-CPR-0135

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer: Polyseam Ltd
Address: 15. St. Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK
Product: GRAFT FR Graphite Plate
Places of production: A/003
Harmonized requirements: EAD 350454-00-1104, September 2017
Scope of certificate: ETA-21/0345 issued on 09/04/2021
Product area code: 35, Fire stopping, fire sealing and fire protective products

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA-21/0345 and EAD 350454-00-1104 under system 1 (or 1+) for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 30th July 2021 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The validity of the certificate may be confirmed by contacting UL International (NL) B.V. via e-mail address info.nl@ul.com

Revision: 2
Date of revision: 27th January 2022

Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 

Name: Horst Thelen
Head of Notified Body

EC CERTIFICATE

Schedule for certificate No. 2821-CPR-0135

General Information

Product Reference:	GRAFT FR Graphite Plate
Type:	Firestop - Preformed, self-adhesive intumescent sheet used as a penetration seal
Description:	A preformed, self-adhesive intumescent sheet used to reinstate the fire resistance performance of wall constructions where they have been provided with apertures for the penetration of cables into socket boxes, on both sides or one side of the wall.
Key Performance parameters:	See ETA-21/0345
Identification and intended use	GRAFT FR Graphite Plate is supplied pre-cut to size with a peel off strip to one face to protect the adhesive layer. The GRAFT FR Graphite Plate is installed by removing the peelable strip and placing the pad to the back face, within the socket box.
CE marking method	Label on packaging
UL Project:	4789972801

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, the Technical Data Sheet and the ETA.
Limitations	See Technical Data Sheet and the ETA

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE

Revision: **2**
Date of revision: **27th January 2022**

Issued by UL International (NL) B.V. Notified Body 2821.

Signed:



Name: **Horst Thelen**
Head of Notified Body

Page 2 of 2