

Certificate

On 23th April 2007 Eurofins Product Testing A/S received a sample of a resilient floor covering with the name

Touch Duet Forbo Flooring Systems

The floor covering sample has been selected by Forbo Flooring Systems as being representative for the floor covering.

The emissions were tested according to the AgBB-scheme and guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 758249D.

Evaluation of the test result according to AgBB guidelines:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m³.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m³.
 - The sum of SVOC after 28 day was below the limit of 0.1 mg/m³.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m³.
 - Formaldehyde after 28 days was below the limit of 120 µg/m³.
-

The tested product complies with the requirements of DIBt (June 2004) in combination with the NIK values from AgBB (September 2005) for use in the indoor environment.

1st April 2008



Thomas Neuhaus
Head of product emission test centre



Marianne Hansen
M.Sc. (Chemistry)

Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 66
Fax +45 70 22 42 55