

Certificate

On 27th of January 2006 Eurofins Danmark A/S received a sample of a floor covering with the name

Surestep PUR Forbo Project Vinyl AB

The floor covering sample has been selected by Forbo Linoleum B.V. as being representative for the floor coverings of the type Surestep.

The emissions were tested according to the AgBB-scheme and guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to EN 13419-1, EN 13419-3, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 753457.

Evaluation of the test result according to AgBB guidelines:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 10.000 µg/m³.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1.000 µg/m³.
 - The sum of SVOC after 28 day was below the limit of 100 µg/m³.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 100 µg/m³.
 - Formaldehyde after 28 days was below the limit of 120 µg/m³.
-

**The tested product is suitable for indoor application,
according to the AgBB guide line (version September 2005).**

30th of March 2006



Thomas Neuhaus
Environmental Engineer



Inge Bondgaard
Chemical Engineer

Eurofins Environment
A/S
Smedskovvej 38
DK-8464 Galten /
Denmark

Tel +45 70 22 42 66