

# CONFIRMATION

## BREEAM-International (2016)

## BREEAM-SE (2017)

### SL025 Vision

supplied by  
Nobia Production Sweden AB

RISE Research Institutes of Sweden AB received from Nobia Production Sweden AB a product sample which is representative of the manufactured product. It has been tested in accordance with relevant test method (ISO 16000-9 with evaluation according to EN 16516), see test report 8P08299-05, dated 2019-02-19.

The test results prove that the product qualifies for BREEAM International (2016, issue 2.0) and BREEAM-SE (2017, v 1.1) requirements in Hea 02, **Exemplary level emission criteria**, for Wood-based products, by complying with:

|  | <b>Formaldehyde</b><br>(mg/m <sup>3</sup> ) | <b>TVOC</b><br>(mg/m <sup>3</sup> ) | <b>TSVOC</b><br>(mg/m <sup>3</sup> ) | <b>Carc. Cat 1A&amp;1B</b><br>(mg/m <sup>3</sup> ) |
|--|---|-------------------------------------|--------------------------------------|--|
| <b>Table 18:<br/>Exemplary level emission criteria</b> | <b>≤ 0.01</b>                               | <b>≤ 0.3</b>                        | <b>≤ 0.1</b>                         | <b>≤ 0.001</b>                                     |
| <b>Test results</b>                                    | <b>&lt; 0.005</b>                           | <b>&lt; 0.010</b>                   | <b>&lt; 0.005</b>                    | <b>&lt; 0.001</b>                                  |

**RISE Research Institutes of Sweden AB**  
Chemistry and Materials - Chemistry

Maria Rådemar

**RISE Research Institutes of Sweden AB**

Postal address  
Box 857  
SE-501 15 BORÅS  
Sweden

Office location  
Brinellgatan 4  
SE-504 62 BORÅS

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@ri.se

This document may not be reproduced other than in full, except with the prior written approval of RISE.