

Confirmation

LEED

On 22 June 2017, Eurofins Product Testing A/S received a sample of a wood based panel with the product name:

GREEN COLLECTION - WOOD

supplied by

Horn Bordplader A/S

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and AgBB testing standards (See test report no. 392-2017-00220601_A_EN).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (February 2015), and the formaldehyde limit of 10 µg/m³ after 28 days

7 August 2017



Maria Pelle Madsen
Analytical Chemist



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.