

Confirmation

LEED

On 29 June 2016, Eurofins Product Testing A/S received a sample of panel with the product name:

Laminat Låge massiv kant

supplied by

SGS-Doors A/S


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and AgBB testing standards (See test report no. 392-2016-00256402_A_EN).

The test results of the tested panel indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days

17 August 2016



Janne R. Norup
Chemist



Maria Pelle
Chemist

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.