

Confirmation

BREEAM[®] NOR 2016

On 25 July 2017, Eurofins Product Testing A/S received a sample of a gypsum board with the product name:

MERO Doppelboden Typ 6

supplied by

MERO-TSK International GmbH & Co. KG

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11 and CEN/TS 16516 in the latest versions (See test report no. 392-2017-00260002_A_EN).

The test results of the tested sample indicate that the product qualifies for BREEAM-NOR New Construction 2016 v1.1 specifications on VOC emissions complying with:

BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria for suspended ceiling tiles according to EN 13964:2014

- TVOC was below the limit of 200 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 28 days
- Formaldehyde was below the limit of 50 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 28 days
- Carcinogenic substances was below the limit of 5 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 28 days

5 September 2017



Maria Pelle Madsen
Analytical Chemist



Janne Rothmann Norup
Analytical Service Manager