

MERO-TSK International GmbH & Co. KG
 Max-Mengeringhausen-Str. 5
 97084 Würzburg
 GERMANY

Eurofins Product Testing A/S
 Smedeskovvej 38
 8464 Galten
 Denmark

VOC@eurofins.com
 www.eurofins.com/VOC-testing

VOC TEST REPORT


Indoor Air Comfort GOLD®

5 September 2017

1 Sample Information

Sample name	MERO Doppelboden Typ 6
Batch no.	-
Production date	03/07/2017
Product type	Gypsum board
Sample reception	25/07/2017

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Regulation of March and April 2011 (DEVL1101903D and DEVL1104875A)
French CMR components	Pass	Regulation of March and April 2011 (DEVL1101903D and DEVL1104875A)
AgBB	Pass	AgBB of February 2015. DIBt of October 2010
Belgian Regulation	Pass	Royal decree of May 2015 (C-2014/24239)
Indoor Air Comfort®	Pass	Indoor Air Comfort 6.0 of February 2017
Indoor Air Comfort GOLD®	Pass	Indoor Air Comfort GOLD 6.0 of February 2017
Blue Angel (RAL UZ 132)	Pass	Low-Emission Thermal Insulation Material and Suspended Ceilings for Use in Buildings, October 2010
BREEAM International	Compliant	GN22: BREEAM Recognised Schemes for VOC Emissions from Building Products
LEED v4 (outside U.S.)	Compliant	LEED v4 for Building Design and Construction (April, 2015)
BREEAM® NOR	Pass	BREEAM-NOR New Construction 2016

Full details based on the testing and direct comparison with limit values are available in the following pages



Maria Pelle
 Analytical Chemist



Janne Rothmann Norup
 Analytical Service Manager

The results are only valid for the tested sample(s).

This report may only be copied or reprinted in its entity, parts of it only with a written acceptance by Eurofins.