



eurofins

Attestation

On 7 February 2011, Eurofins Product Testing A/S received a sample of an adhesive named

UZIN KE 2000 S Uzin Utz AG

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by 09.11.2010. (See report No. G06878B)

Evaluation of the test result according to EC 1 PLUS:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 750 $\mu\text{g}/\text{m}^3$.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 60 $\mu\text{g}/\text{m}^3$.
 - The sum of SVOC after 28 day was below the limit of 40 $\mu\text{g}/\text{m}^3$.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 $\mu\text{g}/\text{m}^3$. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 40 $\mu\text{g}/\text{m}^3$.
 - The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
-

This certificate does not entitle to use the protected trademark label EMICODE. For the use of an EMICODE label a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products, if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

14 July 2011

Thomas Neuhaus
Head of product emission test centre

Martin Møller Pedersen
M.Sc. (Pharm)

Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75