



Confirmation

eurofins

Eurofins Product Testing A/S confirms that a sample of a rubber floor adhesive with the name

Uzin KE 603
supplied by
Uzin Utz AG

showed low VOC emissions in a test in accordance with *California Department of Health Services Standard Practice for The Testing Of Volatile Organic Emissions From Various Sources Using Small-Scale Environmental Chambers, including 2004 Addenda (California Specification Section 01350)*, as specified in LEED for schools credit 4.1 (adhesives and sealants).

Emissions were below all limit values specified in that standard practice.

The test has been performed on 16 October 2009, see test report no. 770905. The testing methodology is covered by independent ISO 17025 accreditation, issued by DANAK (# 168).

With this confirmation, use of product Uzin KE 603 may qualify for fulfillment of LEED for schools credit IEQ 4 (adhesives and sealants).

16 October 2009

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com