



TECHNISCHE
UNIVERSITÄT
MÜNCHEN

**Institut für
Baustoffe und
Konstruktion
MPA BAU**

TUM · MPA BAU – Abteilung Massivbau 80290 München

Contractor:
PCI Augsburg GmbH
Piccardstraße 11
86159 Augsburg

**Materialprüfungsamt
für das Bauwesen
Abteilung Massivbau**

80290 München

Building address:
Theresienstraße 90 / N6
80333 München

Telefon: 0049/89/289-23000
Telefax: 0049/89/289-23046
E-Mail: mpa@mb.bv.tum.de

Short version to the TEST REPORT Nr.: 25090346-1/Gi from 2009-10-28

SUBJECT: Testing of the cementitious adhesive for tiles „PCI Nanolight white“ with
“PCI Lastoflex”

TEST SPECIFICATIONS: DIN EN 12004:2007-11 „Adhesives for tiles - Definitions and specifications“
DIN EN 1308:2007-11 „Adhesives for tiles - Determination of slip“
DIN EN 1346:2007-11 „Adhesives for tiles - Determination of open time“
DIN EN 1348:2007-11 „Adhesives for tiles - Determination of tensile adhesion
strength for cementitious adhesives“
DIN EN 12002:2003-07 „Adhesives for tiles - Determination of transverse
deformation for cementitious adhesives and grouts“

TEST RESULT: The cementitious adhesive for tiles „PCI Nanolight white“ with “PCI Lastoflex”
has fulfilled all requirements of the class

C2TE S2

according to DIN EN 12004:2007-11.

Head of the test laboratory

Dr. G. Winklmeier



Official in charge

Dr. A. Gies-Schuma

English translation - you are advised to use this translation in conjunction with the original language document. In case of doubts, the German language document shall prevail.