

Confirmation

BREEAM[®] NOR 2016

On 22 April 2020, Eurofins Product Testing A/S received a sample of a flooring system with the product name:

Acrylicon Décor System

supplied by

AcryliCon Polymers GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11 and EN 16516 (See test report no. 392-2020-00176001_N_EN_rev1).

The test results of the tested product indicate that the product qualifies for BREEAM-NOR 2016 New Construction v 1.2 specifications on VOC emissions by complying with:

BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria:

- TVOC was below the limit of 200 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 28 days
- Formaldehyde was below the limit of 63 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 3 days
- Formaldehyde was below the limit of 50 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 28 days
- Carcinogenic substances was below the limit of 5 $\mu\text{g}/(\text{m}^2\cdot\text{h})$ after 28 days

24 June 2021



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry