

# Confirmation

## BREEAM<sup>®</sup> NOR 2016

On 28 May 2020, Eurofins Product Testing A/S received a sample of a coating system with the product name:

### Acrylicon Variant System

supplied by

### AcryliCon Polymers GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11 and EN 16516 (See test report no. 392-2020-00228105\_N\_EN\_rev1).

**The test results of the tested product indicate that the product qualifies for BREEAM-NOR 2016 New Construction v 1.2 specifications on VOC emissions complying with:**


**BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria:**

- TVOC was below the limit of 200  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 28 days
- Formaldehyde was below the limit of 63  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 3 days
- Formaldehyde was below the limit of 50  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 28 days
- Carcinogenic substances were below the limit of 5  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 28 days

24 June 2021



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry