

CERTIFICAT OF CONFORMITY OF PARAFON CLINIC N° 15 06 049 – PARAFON CLINIC / 1 Ver.0



Given by : CERA-LABO
ZAC DE TESAN
IMPASSE CARIGNANS N°10
30126 SAINT LAURENT DES ARBRES - France

to : **PAROC OY AB**

Report : **15 06 049 – PAROC – PARAFON CLINIC A 15 / 1 Ver.0** written the 21th july 2015
15 06 049 – PAROC – PARAFON CLINIC A 40 / 1 Ver.0 written the 21th july 2015
15 06 049 – PAROC – PARAFON HYGIENE MICROBIOLOGY / 1 Ver.0 written the 31th july 2015

Conclusions :

The tile PARAFON CLINIC gives the following results:

- The particular class in normal condition face and back is ISO 4 according to the norm ISO 14644-1 : 1999.
- The particular class under vibrations face and back is ISO 4 according to the norm ISO 14644-1 : 1999
- The particular class with a damaged face is ISO 4 according to the norm ISO 14644-1 : 1999
- The microbiological class according to the norm NF S 90-351 : 2013 is :

M100 / area 2	M10 / area 3
Staphylococcus aureus MRSA	Escherichia coli
	Candida albicans

- The painted face of the tile PARAFON CLINIC limits the development of Escherichia coli, Staphylococcus aureus MRSA and Candida albicans.

GENERAL CONCLUSIONS OF TILES PARAFON CLINIC

Classification of Tiles PARAFON CLINIC

Tests		Norms	Acceptance criteria	Results	Conformity
Particle cleanliness class normal condition face		ISO 14644-1	ISO 4	ISO 4	Conform
Particle cleanliness class normal condition back		ISO 14644-1	ISO 4	ISO 4	Conform
Particle cleanliness class Under vibrations face		ISO 14644-1	ISO 4	ISO 4	Conform
Particle cleanliness class Under vibrations back		ISO 14644-1	ISO 4	ISO 4	Conform
Particle cleanliness class With a damaged face		ISO 14644-1	ISO 4	ISO 4	Conform
Air microbiological control	<i>Escherichia coli</i>	NF S 90-351	M10	M10	Conform
	<i>Candida albicans</i>	NF S 90-351	M10	M10	Conform

Remarks

- The microbiological tests as been made under Microbiological Safety Cabinet
- The completed results are in the reports :
 - 15 06 049 – PAROC – PARAFON CLINIC A 15 / 1 Ver.0** written the 21th july 2015
 - 15 06 049 – PAROC – PARAFON CLINIC A 40 / 1 Ver.0** written the 21th july 2015
 - 15 06 049 – PAROC – PARAFON HYGIENE MICROBIOLOGY / 1 Ver.0** written the 31th july 2015

The Director